

AEDARSA Shutdown List - 2021

Date	Device Type	Rationale
04-May	Passenger Traction	Counter Weight is compressing buffer more than 25%
05-May	LPPD Ram Traction	Emergency alarm bell not working/Car safeties not activating as per design
06-May	LPPD	Auxiliary contact switch in mainline disconnect is non functional
10-May	Passenger Hydro	Inproper operation of door restrictor
10-May	Passenger Traction	Car Door Restrictor
11-May	Passenger Hydro	Inproper operation of door restrictor. No emergency light/ alarm or phone.
11-May	Passenger Hydro	Car Door Restrictor
12-May	Vert Encl Roped Hydro	The low pressure switch was not wired into the controller and a jumper was present in its place.
12-May	LPPD Ver. Enclosed	Unit would run with bottom landing door open if unit was not at a floor level
12-May	LPPD Traction	Car safeties not activating as per manufacturers design.
13-May	LPPD Vert Encl Hydro	The Low Pressure did not function as required
13-May	Passenger Traction	Elevator car door detector is non operational
19-May	Passenger Traction	Car Door Restrictor
20-May	LPPD	Car safeties not activating as per manufacturers design.
20-May	Manlift	Repair Emergency Alarm Bell in Manlift. Repair/replace Safety Operating Switch to open safety circuit when Safeties apply during slow speed safety test. Secure Fourth Floor Hall Entrance assembly.
20-May	Passenger Traction	The door detector only works intermittently to stop and reopen the door if an obstruction is present.
21-May	Passenger Hydraulic	Car Door Restrictor
25-May	Passenger Traction	Car Door Restrictor
26-May	Passenger Traction	Multiple breaks in Governor rope. No Alarm or Phone
27-May	Manlift Power type	Floor #4 Hall Door is able to open when Manlift is not present at Floor level.
27-May	Manlift Power type	Floors #1 and #5 Hall Doors are able to be opened when Manlift is not present at Floor Level.
28-May	LPPD-Encl Ball/Screw	Emergency stop button inside the carrier does not remove power from the motor.