

Elevating Devices Shutdown List

Date	Device Type	Rationale
01-Dec	Passenger Traction	Pit switch not operating as required/designed
01-Dec	Passenger Hydro	Restrictor not functioning on front and rear door
01-Dec	Passenger Hydro	Car door restrictor not working
02-Dec	Escalator	Bottom skirt switch not working and SSPI failed (loded gap)
02-Dec	LPPD Ver. Encl	Pressure switch and Slack rope Switch not working
02-Dec	LPPD Hydro	Lift is cavitating and unable to rech full travel(empty)
02-Dec	Escalator	Damaged step treads
03-Dec	Passenger Traction	Car door restrictor not working / One of the hoist ropes is damaged from a shackle rope clip rubbing against/into the live side of the rope
03-Dec	LPPD Stair Pltform	Lift does not make the bottom landing when traveling in the down direction. Faulty slack rope switch causes the rope to unwind from the drive sheave.
06-Dec	LPPD Roped Hydro	LPPD failed drop test. The safeties did not mechanically engage.
06-Dec	Passenger Hydro	Car door restrictor does not function.
06-Dec	Passenger Traction	Car door restrictor does not function.
07-Dec	Passenger Hydro	Car door restrictor does not function/Emergency phone, alarm and lighting not working
07-Dec	LPPD Roped Hydro	Emergency bell not working with the power off. (no emergency phone equipped)
08-Dec	Paas Traction MRL	Replace or regroove the counterweight sheave (cable imprint on every groove)
08-Dec	Passenger Hydro	No min required maintenace or provider in the past 12 months
09-Dec	Pass Traction MRL	The car door restrictor is not engaging
10-Dec	Pass Traction MRL	Car door restrictor does not function.
13-Dec	LPPD Ver. Encl	Lift runs with Hall Door unlocked(bypassed) at Floor #1.
13-Dec	LPPD Ver. Encl	Low pressure switch not working
14-Dec	Passenger Traction	Seal broken on Car Governor.
15-Dec	Passenger Hydro	Emergency 2-way communication, alarm and bell not working
15-Dec	LPPD Vert Encl	Emergency alarm bell not working
16-Dec	Passenger Traction	Car door restrictor does not function.
16-Dec	Passenger Traction	Emergency alarm bell and phone not working
16-Dec	Freight Pltform Type	No maintenance completed or maintenace provider
16-Dec	Passenger Hydro	Emergency phone and alarm bell not working
17-Dec	Freight Traction	Elevator runs with Floor 2 Hall Door in unlocked position Loose wall bricks around rail bracket near top of hoistway and sitting on rail bracket
17-Dec	Passenger Traction	Overspeed governor seal missing
17-Dec	Escalator	Failed SSPI (Exceed 4mm) Brake TQ below MFG spec's/requirements
17-Dec	Escalator	Failed SSPI (Exceed 4mm) Brake TQ below MFG spec's/requirements
17-Dec	Passenger Hydro	Emenrgency alarm bell, phone and Low pressure switch not working
20-Dec	Passenger Traction	Car door restrictor does not function.
21-Dec	LPPD Roped Hydro	Low pressure switch not working
21-Dec	Passenger Traction	Car door restrictor does not function.
21-Dec	LPPD Vert Encl	Repair needed on Emergency alarm bell