



## Data Sheet LPPD Platform lifts

<b>GENERAL</b>	Date:		Elevator Class:	LPPD
	Unit Number:		Elevator Type:	
	Address:		# of Floors:	
	City:		Capacity:	
	Contractor:		Speed: (0.15/0.25)m/s	

<b>GENERAL REQUIREMENT</b>	Enclosed / Unenclosed		Travel & Projection	
	Floor Penetration		Max Travel (enclosed 7m Unenclosed 2.5m)	
	Landing Vertical Clearance > 2 m		Beveled Projection (15° if < 30mm)	
	Protection against Hazard, Falling		Data Plate	

<b>LOAD TEST</b>	No Load			Full Load		
	Current	Volt	Speed	Current	Volt	Speed
			▲			▲
			▼			▼
	Disconnect Switch Fuse Rating			Terminal Stopping Device Down		
	Disconnect Switch Volt Rating			Working Pressure		
	Terminal Stopping Device Up			▲	Relief Pressure	
	Working Pressure			Anti-Creep Leveling		

<b>DRIVE</b>	Safety Test, Slack Rope	▼	Connections & Fittings	
	Electrical Switch		Shutoff Valve	
	Flexible Hose & Fitting		Speed-Limiting Devices	
			Emergency Lowering	

<b>RUNWAY</b>	Enclosure, solid, smooth		Guide Rails	
	Landing Doors & Gate		Horizontal Clearances (min 50)	
	Mechanical Limits		Under Platform Access	
	Stop Switch		Max Travel (enclosed 7m Unenclosed 2.5m)	
	Pit Depth / Mechanical Means		Suspension Means	

<b>CARRIAGE</b>	Capacity Plate		Location of Buttons (890-137)mm	
	Emergency Bell		Guards for Attendant Platforms	
	Car Call Button		Warning Signal (when moving No Direct	
	Emergency Stop Switch		Top of Car Stop Switch	
	Light (100lx)		Safety Flaps & Handrails	
	Emergency Light (2 lx)		Platform Max Area 1.3 m	

Note:

EDA 099/rev1.15

- Where there is a conflict between this Guideline & the Act & Regulations the regulations shall prevail.
- FOIP** "The personal information is being collected in support of the administration of the *Safety Codes Act*. The authority to collect the personal information is made pursuant to section 33(c) of the *Freedom of Information and Protection of Privacy (FOIP) Act*, and will be managed in accordance with the privacy provisions of the *FOIP Act*. If you have any questions regarding the collection of this personal information, please contact the Alberta Elevating Devices and Amusement Rides Safety Association at 104,861651Ave, Edmonton, T6E6E6 or by telephone at 1-800-222-7281.